Springstead

What modelling data are you using for projected rain fall to inform rainwater harvesting? (David Fletcher)

At Springstead we base the rainwater-harvesting calculation on Met Office long-term averages for Cambridge (NIAB), 1991–2020.

https://www.metoffice.gov.uk/research/climate/maps-and-data/location-specific-long-term-averages/u1214qgj0

These monthly and annual rainfall data provide the yield input. At detailed design, storage sizing will follow the National SuDS Standards, which require rainwater-harvesting systems to be designed to BS EN 16941 and evidenced against an appropriate rainfall time series.

Marleigh

GCPS to provide agreed play provision for Phase 2 and 3 (Laurence Moore)

GCPS to share agreed Parking Strategy for Phase 3 (Laurence Moore)

Please find attached presentation

Newmarket Park and Ride

Cambridge County Council to confirm the agreed details of how the Newmarket Road park and ride site is being used by Marleigh Academy and the agreed drop off point in the event of relocation of the Newmarket Park and Ride (Jez Tuttle)